



Proposed Code Change

State Form 41186R

RETURN TO:
INDIANA DEPARTMENT OF HOMELAND SECURITY
CODE SERVICES SECTION
302 W. Washington Street Room W246
Indianapolis, IN 46204

FOR OFFICE USE ONLY

Received 12/29/09

Code 52.10.7-09

INSTRUCTIONS:

Only TYPED copy accepted.

(KEY – ~~Dashed line through material to be deleted~~, underline material to be added)

Use second sheet for any material requiring more space.

Code Title International Residential Code		Edition 2009
Section number and title G2404.10 Auxiliary drain pan		Page 519
Proponent Calvin Bolt	Title	
Address 1310 Oriole Dr., Warsaw, IN 46580		Phone 574-269-3507
PROPOSED CODE CHANGE (Check One)		
<input checked="" type="checkbox"/> Change to read as follows <input type="checkbox"/> Add to read as follows <input type="checkbox"/> Delete and substitute as follows <input type="checkbox"/> Delete without substitution		
<p>Change Section G2404.10 Auxiliary drain pan to read as follows: Category IV condensing appliances shall be provided with an auxiliary drain pan where damage to any building component will occur as a result of stoppage in the condensate drainage system <u>when installed over a finished ceiling</u>. Such pan shall be installed in accordance with the applicable provisions of Section M1411.</p> <p>Exception: An auxiliary drain pan shall not be required for appliances that automatically shut down operation in the event of a stoppage in the condensate drainage system.</p>		
REASON AND FISCAL IMPACT		
<p>This proposal brings forward an amendment from the 2005 Indiana Residential Code.</p>		
REVIEW RECOMMENDATION		
Approve		
Disapprove		
Approve as amended		
Further Study		